



Industrie Service

Herewith is granted the right to the company

## Rosenberg Ventilatoren GmbH

in

D-74653 Künzelsau - Gaisbach

for the operated fan test rig

### „Großer Prüfstand“

located in

D-74653 Künzelsau – Gaisbach

for the volumetric flow range of 3,000 m<sup>3</sup>/h to 40,000 m<sup>3</sup>/h and a pressure range up to 1,500 Pa,

based on the positive results of the completed tests regarding compliance with the requirements of the standard

**DIN EN ISO 5801:2018-04**

to identify this with the following  
TÜV SÜD Certification Mark.



This certificate is valid until 2020-12-31

Certificate Registration Number: 08/11/01

  
Certification Body for Products  
Refrigeration and Air-Conditioning  
Munich, 2018-12-28

